

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Mr. Deepak Khane

(Name of Officers with designation) from Assistant Engineer PHED, Jabalpur

inspected the MM International School, Katni - Nagpur Bypass, Jabalpur

(Name & Address of the school) on 25/6/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Report No. -29 dated 25/6/2025

of District Water Testing Laboratory (PHED Lab) Jabalpur certified that the

MM International School, Jabalpur (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six Month

[Signature]
Assistant Engineer
P.H.E. Sub-Division

Signature with Seal: Jabalpur

Name: Mr. Deepak Khane

Designation: Assistant Engineer

Name & Address of the Office / Department: A.E. PHED
Jabalpur

To
MM International School
Katni - Nagpur Bypass Road, Jabalpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]

Manager

MM International School
Katni-Nagpur Bypass Jabalpur

[Signature]

Principal

MM International School
Katni Nagpur Bypass Jabalpur
School Code-50813
Affiliation No. 1030850

DISTRICT WATER TESTING LABORATORY

Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report no <u>99</u>	Date <u>25/06/2025</u>	Code no. -
Ref. NO - <u>Nil</u>	Date <u>25/06/2025</u>	GP/Village & Location
To, MM International School Katni - Nagpur Bypass Road Jabalpur (M.P.)		Block <u>Jabalpur</u>
		1. MM International School Katni - Nagpur Bypass Road, Jabalpur, RD water sample
Sample Collected by <u>Shubham Shrivastava</u>		
Date of collection <u>25/06/2025</u>		
Source <u>RD Water</u>		
Date of receipt <u>25/06/2025</u>		
Date of Testing <u>25/06/2025</u>		
Test conducted by <u>Kavita Rajak</u>		

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	RESULT				
					1	2	3	4	5
PHYSICAL-TEST									
1	Turbidity	NTU	1.0	5.0	1.1				
2	Colour	Pt. Cobalt			7				
3	Taste & Odour	Unobjectionable	Unobjectionable		-				
CHEMICAL-TEST									
4	pH	...	6.5 to 8.5	6.5 to 8.5	8.17				
5	Conductivity	μMols/cm	184				
6	Alkalinity	mg/l	200	600	140				
7	Chloride (As Cl)	mg/l	250	1000	40				
8	Nitrates	mg/l	45	45	0.0				
9	Total Hardness (As CaCO ₃)	mg/l	200	600	270				
10	Calcium (As Ca)	mg/l	75	200	52.0				
11	Magnesium (As Mg)	mg/l	30	100	34.09				
12	Total dissolved solid	mg/l	500	2000	119				
13	Iron (As Fe)	mg/l	1.00	1.0	0.0				
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0				
15	Fluoride (As F)	mg/l	1.00	1.50	0.0				
16	Sulphates As SO ₄	mg/l	200	400	0.34				
17	Residual Chlorine	mg/l	0.20	1.0	-				
BACTERIOLOGICAL-TEST									
18	Total Coliform	per 100ml	0	..	-				
19	E Coli or Thermo tolerant coliforms or Faecal coliform	per 100ml	0	..	-				

Note:- 1.As above result compared with BIS 10500:2012

2.Samples are not collected by us.

3.Not to be produced at court of law.

4.We do not take any responsibility for deviation in test result due to wrong collection of sample

Manoj

Manager

MM International School
Katni-Nagpur Bypass-Jabalpur

Asst Chemist
Asst Chemist
Public Health Engg. Division
Jabalpur (M.P.)

Principal

MM International School
Katni Nagpur Bypass Jabalpur
School Code-50813
Affiliation No. 1030850

testing formate 29.08.